

2430 "E" Street, N. W.
Washington, D. C.
4 November 1953

25X1A9a



1. Fresh Air Dampers
2. Volume Damper for Special Room

25X1A9a

Dear Mr. [REDACTED]:

Reference is made to your letter of 29 October 1953, same subject.

1. The suggestion by the [REDACTED] of a 48"x12" Minimum Damper and a 48"x48" Maximum Damper has our approval.

25X1A

2. In view of the fact that the volume damper for the Special Room is not considered necessary, instruct the Contractor to omit the thermostat and allow proper credit for same.

Very truly yours,

25X1A9a

